

Technical Exhibit 11

Infrastructure Systems

As part of the service provider's basic services (fixed price), the following are important infrastructure systems which shall have system and database back-ups performed according to the following chart:

<u>Software System</u>	<u>Periodicity of Backup</u>
BAS-Siemens	semi- annual (or after software change)
Lithonia Lighting	semi- annual (or after software change)
Simplex Fire Alarm	annual (or after software change)
MCC Audio-Visual Equip.	annual (or after software change)
MCC RUPS system (Piller)	annual (or after software change)
Security System (TBD*)	(TBD*)
Annex HVAC (Johnson Controls)	semi- annual (or after software change)
Annex HVAC (Liebert)	semi- annual (or after software change)
Fire Alarm system (FCI)	semi- annual (or after software change)
Annex RUPS system (Piller)	semi- annual (or after software change)
CMMS - PM recordation (**)	Weekly – subject to change upon rollout.
Electrical system PLCs	original programming or when modified

TBD – To be determined.

- (*) The current Simplex security system is being replaced with a Hirsch system. The extent of O&M coverage that will be required for the new system has yet to be determined.
- (**) The current Datastream/MP2 CMMS is being replaced by an Archibus system.